

Zibo Feiyuan Chemical Co.,Ltd

Gaoqing Chemical Industry Park, Gaoqing County, Zibo City, Shandong Province, China Tel/Fax:86-533-3589318 website:www.feiyuanchem.com

CERTIFICATE OF ANALYSIS

Product Name:R410a

Batch No.: 20240322-V1510-3 Standard: AHRI700-2019
Sample Date: 23th Mar. 2024 Inspect Date: 23th Mar. 2024

Inspect Result:

Items	Index	Results
	First grade	
Appearance	Colorless&no turbid	Colorless&no turbid
Smell	No strange stench	No strange stench
Purity (% by Weight) ≥	99.9	99.92
Water (ppm by weight) ≤	0.001	0.00081
Acidity (by weight as HCl) ≤	0.0001	0
Evaporation residue (by weight)≤	0.01	0.0006
Non-absorbable gases (by volume invapour phase) ≤	1.5	0.50
CL	PASS	PASS
Composition	R32:R125	49.74:50.26
Conclusion : Excellent Grade		
Remark:		

Sample: Geng Xuejiao Analyze:Geng Xuejiao

Signed