

CERTIFICATE OF ANALYSIS

Product Name:R507A

Batch No.: 20240323-R507A-1

Standard: AHRI700-2019

Sample Date:23th Mar. 2024

Inspect Date:23th Mar. 2024

Inspect Result:

Items	Index	Results
	First grade	
Appearance	Colorless&no turbid	Colorless&no turbid
Smell	No strange stench	No strange stench
Purity (% by Weight) \geq	99.9	99.92
Water (ppm by weight) \leq	0.001	0.00076
Acidity (by weight as HCl) \leq	0.0001	0
Evaporation residue (by weight) \leq	0.01	0.0006
Non-absorbable gases (by volume in vapour phase) \leq	1.5	0.59
CL	PASS	PASS
Composition	R143:R125	49.74:50.26
Conclusion : Excellent Grade		
Remark :		

Sample: Geng Xuejiao

Analyze:Geng Xuejiao

Review: Tao Lianxiu

Signed By

